

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 51

Dated: 23-02-2026

It is certified that an inspection team headed by Sri Karan Soen  
(Name of Officers with designation) from Assistant Executive Engineer  
(Name of Department/ Office) inspected the RWS&S Section, Champur  
(Name & Address of the school) on 23-02-2026 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of One Year.

Signature with Seal: .....

Name : .....

Designation : .....

Karan  
23/02/26  
Assistant Executive Engineer  
RWS&S Section, Champur

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To

The Principal  
Chandrasekhar English Medium School, Champur

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

# SUB-DIVISION WATER TESTING LABORATORY RWS&S SUB-DIVISION, CHAMPUA

At/PO -Champua, Dist-Keonjhar  
Odisha, Pin: 758041

Email: labrwsschampua@gmail.com

## DRINKING WATER ANALYSIS REPORT



Lab Ref. No. 116/2025-26

Dated 27.02.2026

To

The Principal  
Chandrasekhar English Medium School, Champua  
AT/PO- Champua Dist-Keonjhar Odisha, 758041  
Type of source- Deep Borewell  
Sample Receive Date -23.02.2026


<b>Test Result</b>					
Test started on-24.02.2026			Test completed on-26.02.2026		
Sl. No.	Name of the Parameters	Unit	Results obtained	Requirements IS:10500:2012	
				Acceptable Limit	Permissible Limit in absence of alternate source
1	Temperature	°C	25.8	-----	-----
2	pH		6.62	6.50-8.50	No relaxation
3	Turbidity	NTU	0.6	1.00	5.00
4	TDS	mg/l	157	500	2000
5	Chloride	mg/l	28	250	1000
6	T.Alkalinity as CaCO <sub>3</sub>	mg/l	88	200	600
7	T.Hardness as CaCO <sub>3</sub>	mg/l	108	200	600
8	Calcium (as Ca)	mg/l	17.64	75	200
9	Magnesium (as Mg)	mg/l	15.55	30	100
10	Fluoride	mg/l	0.71	1.0	1.5
11	Iron	mg/l	0.08	0.3	1.0
12	Elect. Conductivity	uScm	241.5	1000	1000
13	Total Coliform	MPN/100 ml	0	0	0
14	E. Coli	MPN/100 ml	0	0	0

Note: As per above parameters tested water is potable

Information on Test Report:

Results relates only to sample received in the Laboratory.

----- End of Report-----

  
 Lab Chemist  
 Sub-Divisional Water Testing Laboratory  
 Sub Division Water Testing Laboratory  
 RWS&S Sub-Division, Champua  
 RWS & S Sub Division (Champua)